




1 PARTIAL FLOORPLAN - TELCOM
T3.14 SCALE: 1/4" = 1'-0"

GENERAL NOTES:

- A. FOR VOICE/DATA OUTLETS PROVIDE A SINGLE GANG MUD-RING WITH A 1" CONDUIT FROM THE TOP OF THE MUD-RING TO ACCESSIBLE CEILING SPACE. TERMINATE CONDUIT WITH END CONNECTORS AND THREAD ON PLASTIC BUSHING FOR CABLE PROTECTION. OUTLET SHALL BE AT THE SAME HEIGHT AS ADJACENT POWER OUTLET AND LESS THAN 18" SEPARATION. COORDINATE WITH ELECTRICAL.
- B. COORDINATE ALL DEVICE LOCATIONS WITH LATEST ARCHITECTURAL INTERIOR ELEVATIONS TO VERIFY DEVICES WILL NOT BE OBSTRUCTED.
- C. PROVIDE PULL STRING IN ALL CONDUITS FOR LATER USE.
- D. ALL PENETRATIONS THROUGH FIREWALLS WILL NEED FIRESTOP OF THE APPROPRIATE RATING.

FIRE ALARM AND DETECTION SYSTEM IS A DEFERRED SUBMITTAL SYSTEM REQUIRING THE CONTRACTOR TO COMPLETE THE PERMIT READY DESIGN AND CALCULATIONS AS REQUIRED PER THE AUTHORITY HAVING JURISDICTION. VERIFY BUILDING OCCUPANCY TYPE AND OCCUPANT LOAD WITH ARCHITECTURAL PLANS.

M Consulting Engineers
INC. 2007 S.E. Ash St.
Portland, OR 97214
PHN: (503) 234-0548
FAX: (503) 234-0677
CONTACT: Gary Adovnik




SLCH - ED and Surgery
Samaritan Health Services: Lebanon Community Hospital
525 N. Santiam Highway, Lebanon, OR 97355

ISSUE DATE: 06.05.2015
REVISIONS:

- 9-14-15 OAR REV.
- 10-5-15 SAME DAY REV.
- 05-11-11 CCD-001

PARTIAL FLOORPLAN - TELCOM

T3.14



CLARK KJOS ARCHITECTS, LLC
333 NW 5th Ave.
Portland, OR 97209
Phone: 503/224-4848
Fax: 503/224-7116